

REPORT FOR TESTING TO AS/NZS 4020 PRODUCTS FOR USE IN CONTACT WITH DRINKING WATER

Product Description **Liquid Rubber Spray Grade**
REPORT NUMBER **4007/92.1567**

SAMPLE REFERENCE **130351-0001**

DATE **17/09/2004**

<u>APPENDIX</u>	<u>Time required</u>	<u>RESULTS</u>
C - TASTE OF WATER EXTRACT	14 days	The product passed at an exposure of 5000 mm²/L.
D – APPEARANCE OF WATER EXTRACT	14 days	The product passed at an exposure of 5000 mm²/L.
E - GROWTH OF AQUATIC MICRO-ORGANISMS	7 weeks	The product passed at an exposure of 5000 mm²/L.
F - CYTOTOXIC ACTIVITY OF WATER EXTRACT	7 days	The product passed at an exposure of 5000 mm²/L.
G - MUTAGENIC ACTIVITY OF WATER EXTRACT	7 weeks	The product passed at an exposure of 5000 mm²/L.
H – EXTRACTION OF METALS	4 weeks	Not applicable

Peter Christopoulos
Technical Officer - Microbiology & Product Testing
Australian Water Quality Centre
Private Mail Bag 3, Salisbury SA 5108
Hodgson Rd, Bolivar SA 5110
Phone +61 8 8259 0332
Fax 08 8259 0228